

## Biolytix EcoPod OWTS - Alarm Panel

### DO NOT TURN POWER OFF

Please call Rotorua Lakes Council as soon as possible if you notice any of the following issues with the treatment system:

- **Strong or unusual odours coming directly from the tanks**
- **Loud or unusual noises from the tank or control panel**
- **Alarm sounding or flashing red light**
- **Toilets and Sinks draining slowly**

**Rotorua Lakes Council**

**07 348 4199**

**24/7 on call assistance available**

### IMPORTANT

The Biolytix wastewater system must be maintained and repaired by a Biolytix trained and Registered Technician. Untrained personnel must not attempt to undertake Biolytix EcoPod servicing or repairs. It is important to contact Rotorua Lakes Council promptly if there is a problem or suspected problem. If a system requires repairs and is not attended to promptly, further damage is likely to occur.

Operations & Maintenance Manual can be downloaded at:

[www.rotorualakescouncil.nz/errssownersmanual](http://www.rotorualakescouncil.nz/errssownersmanual)

**Site #:**

**East Rotoiti Rotomā Sewerage Scheme**

**ROTORUA  
LAKES COUNCIL**  
Te Kaunihera o ngā Roto o Rotorua

# Biolytix EcoPod OWTS - Onsite System

All homeowners/tenants/visitors must be aware that this Biolytix system uses patented biological filtration technology, relying on an ecosystem of organisms to treat wastewater on site. Care must be taken to avoid excessive water use, and to avoid harsh chemicals or non-biodegradable items entering the system. Harsh chemicals and non-biodegradable materials can negatively affect the system and result in expensive repairs.

## The following should NOT enter the wastewater system:

### CHEMICALS:

- Bleach (small quantities for laundering and products like Napisan are acceptable)
- Chlorine and other harsh disinfectants
- Caustic soda (NaOH) and other highly alkaline (pH>9.5), or acidic (pH<4) chemicals
- Drain cleaners
- Commercial cleaning products
- Paints and solvents
- Chemicals that are not typically used in a household
- Pesticides and herbicides
- Other toxic substances
- Fats, oils and grease (except from normal kitchen use)

### NON-BIODEGRADABLE MATERIALS:

- Disposable nappies and nappy liners
- Baby wipes and other wet/dry wipes
- Tampons, sanitary pads/napkins etc
- Condoms
- Rags

## IMPORTANT

The Biolytix wastewater system must be maintained and repaired by a Biolytix trained and Registered Technician. Untrained personnel must not attempt to undertake Biolytix EcoPod servicing or repairs. It is important to contact Rotorua Lakes Council promptly if there is a problem or suspected problem. If a system requires repairs and is not attended to promptly, further damage is likely to occur.

**Rotorua Lakes Council**  
**07 348 4199**

**24/7 on call assistance available**

Operations & Maintenance Manual can be downloaded at:  
[www.rotorualakescouncil.nz/errssownersmanual](http://www.rotorualakescouncil.nz/errssownersmanual)

**Site #:**

**East Rotoiti Rotomā Sewerage Scheme**

**ROTORUA**  
**LAKES COUNCIL**  
Te Kaunihera o ngā Roto o Rotorua

70 x 100mm

This property is serviced by a Biolytix  
EcoPod Treatment System



**IMPORTANT NOTICE**

Please only flush toilet paper  
down the toilet

*Thank You*

**ROTORUA  
LAKES COUNCIL**  
Te Kaunihera o ngā Roto o Rotorua

## Saniflo Lift Pump - Alarm Panel

### DO NOT TURN POWER OFF

Please call Rotorua Lakes Council as soon as possible if you notice any of the following issues with the lift pump system:

- **Strong or unusual odours coming directly from the tank**
- **Loud or unusual noises from the lift pump or control panel**
- **Alarm sounding**
- **Toilets and Sinks draining slowly**

**Rotorua Lakes Council**  
**07 348 4199**  
**24/7 on call assistance available**

### IMPORTANT

The Saniflo Lift pump system must be maintained and repaired by a trained and Registered Technician. Untrained personnel must not attempt to undertake any servicing or repairs on this system. It is important to contact Rotorua Lakes Council promptly if there is a problem or suspected problem. If a system requires repairs and is not attended to promptly, further damage is likely to occur.

Operations & Maintenance Manual can be downloaded at:  
[www.rotorualakescouncil.nz/errssownersmanual](http://www.rotorualakescouncil.nz/errssownersmanual)

**Site #:**